

NB Appendix
PRC-015-1 - Remedial Action Scheme Data and Documentation

This appendix establishes modifications to the FERC approved NERC standard PRC-015-1 for its specific application in New Brunswick. This appendix must be read with PRC-015-1 to determine a full understanding of the requirements of the standard for New Brunswick. Where the standard and appendix differ, the appendix shall prevail.

A. Introduction

- 1. Title:** Remedial Action Scheme Data and Documentation
- 2. Number:** PRC-015-1
- 3. Purpose:** No New Brunswick modifications
- 4. Applicability:**
 - 4.1.** No New Brunswick modifications
 - 4.2.** No New Brunswick modifications
 - 4.3.** No New Brunswick modifications
- 5. Effective Date:** No New Brunswick modifications

B. Requirements

- R1.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall maintain a list of and provide data for existing and proposed RAS as specified in NERC Reliability Standard PRC-013-1_R1.
- R2.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall have evidence it reviewed new or functionally modified RAS in accordance with the NPCC procedures as defined in NERC Reliability Standard PRC-012-1_R1 prior to being placed in service.
- R3.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall provide documentation of RAS data and the results of Studies that show compliance of new or functionally modified RAS with New Brunswick Energy and Utilities Board approved Reliability Standards to NPCC and

NERC on request (within 30 calendar days) as directed by the NBEUB.

C. Measures

- M1.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall have evidence it maintains a list of and provides data for existing and proposed RAS as defined in NERC Reliability Standard PRC-013-1_R1.
- M2.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall have evidence it reviewed new or functionally modified RAS in accordance with the NPCC procedures as defined in NERC Reliability Standard PRC-012-1_R1 prior to being placed in service.
- M3.** The Transmission Owner, Generator Owner, and Distribution Provider that owns a RAS shall have evidence it provided documentation of RAS data and the results of studies that show compliance of new or functionally modified RAS with New Brunswick Energy and Utilities Board approved reliability standards to NPCC and NERC on request (within 30 calendar days) as directed by the NBEUB.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Responsibility

New Brunswick Energy and Utilities Board

1.2. Compliance Monitoring Period and Reset Timeframe

No New Brunswick modifications

1.3. Data Retention

No New Brunswick modifications

1.4. Additional Compliance Information

No New Brunswick modifications

2. Levels of Non-Compliance

NB Appendix
PRC-015-1 - Remedial Action Scheme Data and Documentation

- 2.1. Level 1:** RAS owners provided RAS data, but was incomplete according to the NPCC RAS database requirements.
- 2.2. Level 2:** RAS owners provided results of studies that show compliance of new or functionally modified RAS with the NERC Planning Standards, but were incomplete according to the NPCC procedures for NERC Reliability Standard PRC-012-1_R1.
- 2.3. Level 3:** No New Brunswick modifications
- 2.4. Level 4:** No RAS data was provided in accordance with NPCC RAS database requirements for NERC Standard PRC-012-1_R1, or the results of studies that show compliance of new or functionally modified RAS with the New Brunswick Energy and Utilities Board approved Reliability Standards were not provided in accordance with NPCC procedures for NERC Reliability Standard PRC-012-1_R1.

E. Regional Differences

- 1.** No New Brunswick modifications

Version History (maintained by NBEUB)

Version	NBEUB Approval Date	NB Appendix Effective Date	Change Tracking	Comments
0	07/12/16	10/01/17	1. Revised Sections B, C and D to clarify that the named standards are no NBEUB approved	Approved Under NBEUB Matter 323

NB Appendix
PRC-015-1 - Remedial Action Scheme Data and Documentation

			standards	
			2. Revised Sections B, C and D to replace "Regional Reliability Organization" with "NPCC"	
			3. Revised Sections B, C and D to replace "NERC Reliability Standards " with "New Brunswick Energy and Utilities Board approved reliability standards"	
			4. Revised Sections B and C to add "as directed by the New Brunswick Energy and Utilities Board"	
			5. Revised Sections B, C and D to remove references to NPCC Criteria	
			6. Revised Section	

NB Appendix
PRC-015-1 - Remedial Action Scheme Data and Documentation

			D to clarify the NBEUB as the entity having the compliance monitoring responsibility for NB	